TRI COUNTY WATER AUTHORITY

2013 Reseller Report

This report is intended to provide you with important information about your drinking water and the efforts made to provide safe drinking water.

Este informe contiene información muy importante. Tradúscalo o preguntele a alguien que lo entienda bien.

[Translated: This report contains very important information. Translate or ask someone who understands this very well.]

What is the source of my water?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and groundwater wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Our water comes from the following source(s): Wells located in Missouri River Aluvium

Source Name	Туре		
WELL # 5	Ground Water		
WELL # 1	Ground Water		
WELL # 2	Ground Water		
WELL # 3	Ground Water		
WELL # 4	Ground Water		

Source Water Assessment:

The Department of Natural Resources conducted a source water assessment to determine the susceptibility of our water source to potential contaminants. This process involved the establishment of source water area delineations for each well or surface water intake and then a contaminant inventory was performed within those delineated areas to assess potential threats to each source. Assessment maps and summary information sheets are available on the internet at http://maproom.missouri.edu/swipmaps/pwssid.htm. To access the maps for your water system you will need the State-assigned identification code, which is printed at the top of this report. The Source Water Inventory Project maps and information sheets provide a foundation upon which a more comprehensive source water protection plan can be developed.

Why are there contaminants in my water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Contaminants that may be present in source water include:

- A. Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- B. Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.
- C. Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- D. Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- E. Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the Department of Natural Resources prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Department of Health regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Is our water system meeting other rules that govern our operations?

The Missouri Department of Natural Resources regulates our water system and requires us to test our water on a regular basis to ensure its safety. Our system has been assigned the identification number MO1071079 for the purposes of tracking our test results. Last year, we tested for a variety of contaminants. The detectable results of these tests are on the following pages of this report. Any violations of state requirements or standards will be further explained later in this report.

How might I become actively involved?

If you would like to observe the decision-making process that affect drinking water quality or if you have any further questions about your drinking water report, please call us at 816-796-4100 to inquire about scheduled meetings or contact persons.

Do I need to take any special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Special Lead and Copper Notice:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. TRI COUNTY WATER AUTHORITY is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (800-426-4791) or at https://water.epa.gov/drink/info/lead/index.cfm.

THE COUNTY WATER AUTOCIA

the meaning visites to receive the form the first transfer interest which are received to the meaning of the second transfer and transfe

VIVal v aemon raor rovelamies, is est sent on the fire

The Aller of the Committee of the Aller of the Committee of the Aller of the Aller

Solve a Amue

7 % 35 MV 3 W 15 MV

NA LIGHT

no et noces i la della co

0.3 h sa ni se ni Hillianio asserii sisaasi 0.5 f k. s. niin m<u>erwored haw, jobe ni 6.5</u>2 h 2. niin merit ni Nivernio 2. 6 h f. 685 s. niita

pendesvati an accument

THE REPORT OF THE PROPERTY OF

and the second of the second o

энственный машка рецест в 150 м с 14 км, репуткция в политов. Она вые Адонку в карасуя, бесу сучен не бей (\$400 м 20, 17.9 %).

re i de la Dan verior e principi de la desentra de la carre la

Charles to Be and the Control of the

Revisero a ristil se de yane mivide estriction.

a digla șii priopă hose flucius rema. Vince a lichie ametinia a signi-

the country to the property of the country of the c

The first of the second se

STATE OF PARTY AND DESCRIPTION TO THE ASSESSMENT OF MARKET AND PARTY.

and the state of the proposition dust sign are sentent to restrict an extensional and the state of the state of

The state of the s

TV SPACE IS CONTROL

20 60 00 00

te of principal control of the contr

The Marine State of the Control of t

TRI COUNTY WATER AUTHORITY

2013 Reseller Report

Contaminants Report

Definitions:

MCLG: Maximum Contaminant Level Goal, or the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety. MCL: Maximum Contaminant Level, or the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

AL: Action Level, or the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.

TT: Treatment Technique, or a required process intended to reduce the level of a contaminant in drinking water.

90th percentile: For lead and Copper testing. 10% of test results are above this level and 90% are below this level.

Level Found: is the average of all test results for a particular contaminant.

Range of Detections: Shows the lowest and highest levels found during a testing period, if only one sample was taken, then this number equals the Level Found.

MRLDG: Maximum Residual Disinfectant Level Goal, or the level of a drinking water disinfectant below which there is no known or expected risk to health.

MRDL: Maximum Residual Disinfectant Level, or the highest level of a disinfectant allowed in drinking water.

RAA: Running Annual Average, or the average of sample analytical results for samples taken during the previous four calendar quarters.

LRAA: Locational Running Annual Average, or the locational average of sample analytical results for samples taken during the previous four calendar quarters.

Abbreviations:

TTHM: Total Trihalomethanes (chloroform, bromodichloromethane, dibromochloromethane, and bromoform) as a group.

HAA5: Haloacetic Acids (mono-, di- and tri-chloracetic acid, and mono- and di-bormoacetic acid) as a group.

ppb: parts per billion or micrograms per liter.

ppm: parts per million or milligrams per liter.

n/a: not applicable.

NTU: Nephelometric Turbidity Unit, used to measure cloudiness in drinking water.

MFL: million fibers per liter, used to measure asbestos concentration.

nd: not detectable at testing limits.

The state has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Records with a sample year more than one year old are still considered representative.

Regulated Contaminants

Regulated Contaminants	Collection Date	Highest Value	Range (low – high)	Unit	MCL	MCLG	Typical Source
BARIUM	5/16/2011	0.0493	0.0493	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
CHROMIUM	5/16/2011	1.72	1.72	ppb	100	100	Discharge from steel and pulp mills
FLUORIDE	5/16/2011	0.17	0.17	ppm	4	4	Natural deposits; Water additive which promotes strong teeth
NITRATE-NITRITE	11/20/2013	0.11	0.11	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Disinfection Byproducts	Period	RAA	(low – high)	Unit	MCL	MCLG	Typical Source
TTHM	2008 - 2010	3	2.61	ppb	80	0	Byproduct of drinking water disinfection

Microbiological	Result	MCL	MCLG	Typical Source
No Detected Results were Found in t	he Calendar Year of 2013			

Violations and Health Effects Information

During the 2013 calendar year, we had the below noted violation(s) of drinking water regulations.

Compliance Period Analyte Type No Violations Occurred in the Calendar Year of 2013

Optional Monitoring (not required by EPA)

Monitoring

Optional Contaminants

Secondary Contaminants	Collection Date	Your Water System Highest Value	Range (low/high)	Unit	SMCL
ALKALINITY, CACO3 STABILITY	5/16/2011	67.8	67.8	MG/L	
CALCIUM	5/16/2011	16.3	16.3	MG/L	
CHLORIDE	5/16/2011	21.5	21.5	MG/L	250
HARDNESS, CARBONATE	5/16/2011	111	111	MG/L	
IRON	5/16/2011	0.0314	0.0314	MG/L	0.3
MAGNESIUM	5/16/2011	17.1	17.1	MG/L	
MANGANESE	5/16/2011	0.00106	0.00106	MG/L	0.05
PH	5/16/2011	8.2	8.2	PH	8.5
POTASSIUM	5/16/2011	6.28	6.28	MG/L	
SODIUM	5/16/2011	38	38	MG/L	
SULFATE	5/16/2011	100	100	MG/L	250
TDS	5/16/2011	263	263	MG/L	500
ZINC	5/16/2011	0.00376	0.00376	MG/L	5

YW COUN'TY WAYTER, A BTHOTE. 2015 Robellachtenan

> oneminari tevel Gentur ibe restot a comunicat in eminir a water top at which even is novertary to a violation post tevere a not embre we seek violates to cause to a more to also

The state of the s

ing and the second of the period of the peri

rugaday (Jad, year) te mesawa dou amaka yi or ordengayatay.

A contract the contract of the property of a management of contract of contract of the contrac

The second of th

anne de la company de la compa

difference of the second secon

AME you be those